



Town of Goffstown

DEPARTMENT OF PUBLIC WORKS

LEGAL NOTICE ADVERTISEMENT FOR BID

2009 Road Resurfacing Bid

The Department of Public Works of the Town of Goffstown, New Hampshire wishes to solicit bid proposals for the Hot Bituminous Asphalt Pavement (machine method) road resurfacing and shimming, asphalt Cape Cod berm and sidewalk paving as directed in accordance with NHDOT Standard Specifications located in the Town of Goffstown.

Information for bidders (Plans, Specifications, Forms, etc.) will be available at the Department of Public Works Office, 404 Elm Street, Goffstown, New Hampshire 03045.

Bid proposals will be accepted on enclosed bid forms and must state the price clearly. All proposals must be in a sealed envelope and marked clearly "**2009 Road Resurfacing Bid**" and received no later than 3:00 P.M. on Wednesday, April 1, 2009. Bids will be publicly opened and will be read at that time by the Goffstown Public Works Director or designee and the Town Administrator or designee at the Town Hall. Notification will take place after bids have been reviewed by the Department of Public Works and a recommendation is made to, and then awarded by, the Board of Selectmen.

Submit Bids To: Office of the Board of Selectmen
16 Main Street
Goffstown, New Hampshire 03045

The successful bidder shall furnish a 100% **PERFORMANCE BOND AND PAYMENT BOND** and shall be required to execute the contract agreement within ten (10) days following notification of the acceptance of his bid. The owner reserves the right to reject any or all bids, to accept any bid, to waive any informality on bids received, or to omit and/or alter any bid item.

*****Copies of plans and specifications may be obtained from Spiller's Reprographics, 880 Second Street, Manchester, NH 03102 (Mon-Fri 7:30 A.M. - 5:00 P.M.) It is suggested that anyone wishing to pick up plans call in advance as they will be printed as requested. Their phone number is 603-644-3336 or 1-800-564-1559. Spiller's Reprographics accepts cash, checks or most major credit cards.



Town of Goffstown

DEPARTMENT OF PUBLIC WORKS

Addendum #1

2009 Road Resurfacing Bid

We have had several questions asked that we feel need to be clarified for all the potential bidders. Below are the questions and the answers:

Question: What is the amount of the Bid Bond?

Answer: The Bid Bond amount is 10%.

Question: In several areas of the project description the task of "grading edges" is used, what is meant by "grading edges"?

Answer: Bidders can strike the term "grading edges" from the project description. The Department of Public Works will do shouldering after the overlays are complete.

Question: In Section 03150 Reclaim Bituminous Concrete Pavement – which method should we bid?

Answer: The specification assumes a job completely contracted out which is not the case for this particular job which will be subcontracting to in-house DPW forces. You can assume (for pricing purposes) that we will use Section 3.02.2 Method B provided the finished product meets the final specification. A second pass may be required to meet specification. We do not use the Calcium Chloride injection. The contractor will rough grade the reclaimed roadway to allow the passage of traffic. If fabric is needed, DPW forces will place the geotextile below the reclaimed material. When that is complete, the contractor will bring in a sheepfoot roller for final compaction prior to fine grading for pavement. The contractor will also do the fine grading prior to paving.

Under General Conditions: Strike section 25.6 Builder's Risk Insurance from the RFP.